



**AIR QUALITY
ENGINEERING**

Tailored solutions from people who care

► **SMOKEMASTER® (F72)** **Electronic Air Cleaner Owner's Manual**



Air Quality Solutions for Commercial Kitchen Exhaust

SMOKEMASTER® F72 Introduction

F72 effectively removes a broad range of contaminants including coolant mist, dust, soot, pollen, tobacco, grease and cooking smoke from the air. One, two or four electronic cells, operated by high voltage power supplies remove airborne contaminants at efficiencies as high as 99 percent and at rates starting at 1000 cfm.

Optional HMI (Human Machine Interface) screen could be installed remotely in convenient location.

HMI screen is connected by Ethernet cable to one unit PLC or to multiple units through Ethernet switch. On HMI screen user can select the unit to modify the settings. Max number of units per HMI is eight. All settings used in the unit PLC are accessible (you can change them) from HMI screen.

Before you get started please review the following:

Purchase Date: _____ Serial Number: _____

Customer Technical Support:

To contact Air Quality Engineering, Inc. use:

Mail: Air Quality Engineering, Inc.
7140 Northland Drive N.
Minneapolis, MN 55428
USA

Phone: 1-800-328-0787
763-531-9823
Fax: 763-531-9900

e-mail: info@air-quality-eng.com
Web: www.air-quality-eng.com

Copyright

Air Quality Engineering, Inc. copyrights this manual with all rights reserved. Under the copyright laws, this manual may not be reproduced in any form, in whole or in part, without the prior written consent of Air Quality Engineering, Inc.

© 2019

Disclaimer

All statements, technical information and recommendations in this manual or related documents are believed reliable, but the accuracy and completeness thereof are not guaranteed or warranted, and they are not intended to be, nor should they be understood to be representation or warranties concerning the products described.


Specifications are subject to change without notice.

	Page
How Airborne Contamination is Removed	3
Dimensions.....	4
Specifications	6
Planning the Installation	7
Assembly & Installation	11
Checkout.....	16
Maintenance	17
Troubleshooting.. ..	20
ANSUL Pre-Piping.....	21
Warranty.....	29


How Airborne Contamination is Removed

A process called “Electrostatic Precipitation” traps airborne contaminants. The fan draws particulate laden air successively through the prefilter, the cell ionizing section and the cell collector section. The ionizing section imparts an electrical charge to the individual particles that are then drawn by electrostatic forces to the oppositely charged collector plates.


The electronic cells must be washed periodically to maintain efficient performance.



F72A




F72B



All measurements in inches.

F72C



All measurements in inches.

METRIC CONVERSION	FORMULA
Ins. to mm	Ins. x 25.4
Lbs. to kgs.	Lbs. x .455
Ins. w.g. to kPa	Ins. w.g. x .2488
CFM to m ³ /h	CFM x 1.6992
Ft ² to m ²	Ft ² x .0929

	SHIPPING WEIGHT		INSTALLED WEIGHT	
	Lb.	Kg.	Lb.	Kg.
F72A	280	127	235	107
F72B	350	159	315	143
F72C	615	279	545	247

- IMPORTANT -

THE SPECIFICATIONS GIVEN IN THIS PUBLICATION DO NOT INCLUDE NORMAL MANUFACTURING TOLERANCES. THEREFORE, THIS UNIT MAY NOT MATCH THE LISTED SPECIFICATIONS EXACTLY. ALSO, THIS PRODUCT IS TESTED AND CALIBRATED UNDER CLOSELY CONTROLLED CONDITIONS AND SOME MINOR DIFFERENCES IN PERFORMANCE CAN BE EXPECTED IF THOSE CONDITIONS ARE CHANGED.

Specifications

- Cabinet:** 16 and 14 gauges welded steel cabinet with a powder coat finish
- Instrumentation:** Indicator Light – Light indicates that the collector cells are energized properly
- Electrical Rating:** 120V/240V, 60 Hz; or 220-240V, 50 Hz
- Ambient Temperature Rating:** 131° F (55° C) Max; -4° F (-20° C) Outside of exhaust airflow
- Power Ratings:** 115V, 1.5 Amps; 230V, 0.75 Amps
- Pre/post Filter:** F72A: two 24" x 24" x 1" heavy duty aluminum mesh filters
F72B: four 24" x 24" x 1" heavy duty aluminum mesh filters
F72C: eight 24" x 24" x 1" heavy duty aluminum mesh filters
- Primary Filter Options:** F72A: one 24" x 24" x 10.75" or two 24" x 12" x 10.75" electronic cells
F72B: two 24" x 24" x 10.75" or four 24" x 12" x 10.75" electronic cells
F72C: four 24" x 24" x 10.75" or eight 24" x 12" x 10.75" electronic cells
- Optional Carbon Filter:** Custom carbon modules available
- Optional Blower Module:** Custom blower modules available
- Optional Enclosure and Mounting:** Optional outdoor weather enclosure and mounting skid available

Air Quality Engineering, Inc. has a policy of continuing product improvement and reserves the right to make changes in design and specifications without notice.

Introduction

Clean air is the subject of numerous laws and regulations. Typical requirements in the United States are those put out by the Occupational Safety and Health Administration (OSHA). Private groups, such as the American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE), have also published numerous recommendations.

Normally, clean air is defined in regulations and recommendations as air having a limited amount of contaminant in it, commonly expressed as parts per million or milligrams per cubic meter. Approved counteractions are intended to lower or eliminate the amount of contaminants in the air. One of the more common methods of achieving this goal is through the use of air cleaners.

Air Cleaner Sizing

The F72 air cleaner is usually sized according to the capacity of the air handling system and the desired efficiency. See Figure 3.

The ASHRAE Standard 62-81, Natural and Mechanical Ventilation, gives recommended quantities of ventilation air in terms of 100 percent outdoor air. The Standard recommends as much as 50 CFM per person ventilation air where people are smoking, such as in a cocktail lounge. These recommended outdoor air quantities may be reduced if air cleaning is provided. However, the Standard recommends that “in no case shall the outdoor air quality be less than five CFM per person.”

The reduction in outside ventilation air required represents the potential for savings through the use of clean recirculated air. This potential for savings can be achieved by a system that reduces particulate and gaseous contaminants to within the ASHRAE recommended limits.

F72 helps to provide this clean, recirculated air by removing particulate contamination (visible smoke). The reduction in outdoor air used, of course, means a reduction in the amount of heating or cooling required. This reduces both operating cost and equipment wear.

Remember that the air cleaner must meet the needs of the user. You are encouraged to use your experience and judgment in the application of this data keeping in mind local codes and minimum air requirements.

Airflow Recommendation with Pressure Drop and Efficiency Rating

F 72 A		F 72 B		F 72 C		Efficiency (Percent)	Pressure Drop	
cfm	M3/ hr	cfm	M3/ hr	cfm	M3/ hr		In.	KPa
1000	1699	2000	3398	4000	6896	99	0.06	0.015
1500	2548	3000	5097	6000	10,194	99	0.12	0.030
2000	3398	4000	6796	8000	13,592	95	0.22	0.055
2500	4248	5000	8495	10,000	16,990	90	0.33	0.083
3000	5296	6000	10,194	12,000	20,388	80	0.49	0.122

Efficiency ratings based on National Bureau of Standards Dust Spot Method and American Society of Heating, Refrigerating and Air-Conditioning Engineers Standard 52-76, using atmospheric dust.

Figure 3 – F72 - Electronic Air Cleaner Capacity and Efficiency

Commercial Applications

When deciding on the number of air cleaners required for applications such as a restaurant, bowling alley, store, bar or lounge, several conditions must be considered. They are:

1. Air to be cleaned of dust, smoke, greases, etc. These conditions may require a higher efficiency in the electronic air cleaner installation.
2. Capacity cubic feet per minute (cfm) of equipment and system.
3. Method of calculation-must be forced air, distributed evenly to all parts of the controlled area with the required air changes per hour.
4. Maximum number and average number of people that will occupy controlled area.
5. The percent operating efficiency required of the electronic air cleaner. F72 efficiency should be from 80 to 99 percent depending on the application and purpose. See Efficiency Chart, Figure 3. The minimum efficiency recommended for commercial kitchen exhaust is 95%.

Contact an Air Quality Engineering, Inc. Representative for assistance on commercial sizing.

Industrial Applications

Sizing is determining how many air cleaning units are required to maintain a desired level of air quality. The process to sizing an industrial application involves roughly figuring the number of air cleaners needed and then modifying the figures according to the specific characteristics of each application.

For ambient air cleaning, the estimated number of electronic air cleaners may be determined by the relationship of air volume to the needed air changes per hour.

An alternative method for calculating the estimated number of electronic air cleaners can be used if it is possible to measure the generation rate of the contaminants and the allowable level of contamination.

To use either method of calculation, contact an Air Quality Engineering, Inc. Representative for assistance on industrial sizing.

Regardless of the method used to calculate the number of units needed to produce clean air, the physical conditions of the space to be cleaned may either limit this number or demand that more units be installed. For ambient air cleaning, it is important to establish a uniform airflow pattern throughout the entire space. Limitations to the calculated sizing may be a lack of space for mounting areas or the number of units may interrupt normal building operation; that is, a unit cannot be mounted where an overhead crane will smash into it or where stand mountings seriously interrupt building traffic patterns. The number of units required by air volume and air changes per hour might need to be increased when the shape of a structure is such capturing and air distribution is not possible according to the sizing calculations that effective.


Location and Position

Because air-handling systems vary greatly in arrangement and style, factors such as location, air distribution, transitions, etc., require careful consideration.

Transitions

When adapting the duct to fit the air cleaner, use gradual transitions in duct size to prevent turbulence and to increase efficiency.

Duct transitions should not exceed 20 degrees (about 4" per lineal foot) on each side of a fitting.



**Figure 5 - Typical Installation with Turning Vanes in Air Duct
(for non-kitchen exhaust applications)**




Figure 4 – Typical Installation

Outdoor Air

When outdoor air is added to the return air duct, sufficient heat must be added to maintain a uniform temperature between 50°F and 125°F. Two methods are recommended:

1. **Baffles.** Mixing baffles should be used to mix the outdoor air and the return air before it enters the air cleaner.
2. **Preheat Coil.** If large amounts of outdoor air are used, it must be heated. An appropriate control system should be used to control the Outdoor air intakes should be hooded or louvered to provide adequate protection from rain and snow. The type of hood used will depend upon the installation and expected weather.

Outdoor air intakes should always be equipped with a "bird screen."

At times it may be desirable to install a prefilter ahead of the electronic air cleaner. This is done to remove contaminants that could be harmful to the air cleaner or might cause excessively fast dirt buildup or arcing in the electronic cell.

Air Conditioning

Make certain the cooling coil is installed **downstream** from the air cleaner cabinet to prevent condensation and chilled air (cooler than 40°F [5°C]) from entering the cell.

Humidifiers

Location of the system humidifier is important to the operation of the air cleaner.

An evaporative type humidifier may be installed between the furnace warm air duct and the return air duct without affecting the electronic air cleaner.

- IMPORTANT -

This section includes information for the sheet metal, plumbing and electrical installation. Make certain each person involved with the installation is aware of the appropriate subsections in the manual.

- CAUTION -

Do NOT connect the power source until after the air cleaner is completely assembled.

If the air cleaner must be turned on for an electrical check, be extremely careful in avoiding electrical shock. Also, take care to avoid the air cleaner's moving parts.

Unpacking

Remove all shipping cardboard and banding. Be sure to inspect the packaging material before discarding it.

When Installing This Product

1. Read these instructions carefully. Failure to follow them could damage the product or cause a hazardous condition.
2. After installation is complete, check out product operation as provided in these instructions.

All components are individually packaged and shipped in one large box. Before proceeding, carefully open each carton and visually check for possible damage to the air cleaner components.

1. Cabinet with electronic cells inside and control box mounted.
2. Drain connection.
3. Accessories, if ordered.

Placement of the Air Cleaner

Depending on the placement of the air cleaner (roof top for example) a lifting crane might be necessary. Make sure that the air cleaner and components are properly supported before lifting.

If placing on a rooftop make sure there is proper clearance between the rooftop and the air cleaner. This can be achieved with mounting beams or by keeping the lifting supports in place.

Sheet Metal Installation

Air Distribution and Ductwork

F72 operates most efficiently when all system air is delivered across the electronic cell at a uniform velocity. Turning vanes should be added to any return airdrop upstream from the air cleaner. See Figure 5.

Gradual transitions to the F72 cabinet are recommended in all ductwork larger or smaller than the cabinet opening. If transitions are used, they should not exceed 20 degrees (4" rise per linear ft).

Install the Air Cleaner

Mount F72 Air Cleaner as Follows:

1. Fabricate and install the necessary vanes and transitions
2. Set the cabinet in position
 - a. If hanging brackets are used, make certain the brackets are strong enough to hold the cabinet and the cabinet is attached firmly to the brackets.
 - b. Leave clearance above the control box to remove the cover.
3. Ductwork preparation
 - a. Drill clearance holes for sheet metal screws in the cabinet which will not cause leaking. Remember that the ductwork must be water-tight near the cabinet.
 - b. Fasten the duct to the cabinet opening with sheet metal screws.
 - c. Use caulking compound (not furnished) to seal the joints and all ductwork joints on both the inlet and outlet sides. Seal all joints for at least 3 ft. from cabinet.

Filter Placement

1. Slide prefilters into shield channels and push all the way to the back of the cabinet.
2. Insert the electronic cells into the cabinet with THIS SIDE OUT label facing the door opening. Make certain the arrow stamped on the cell points downstream. See Figure 6.
3. Close the door.

Electrical Installation

All wiring must comply with applicable local codes and ordinances. The power supply to the F72 air cleaner must be 120V or 240V, 60 Hz, or 220-240V, 50 Hz. Refer to the F72 nameplate for the proper voltage for your air cleaner.




Figure 6 – Correct Cell Orientation




Figure 7 – Internal Wiring Schematic for F72A and F72B without PLC




Figure 8 – Internal Wiring Schematic for F72C without PLC





Figure 9 – Internal Wiring Schematic for F72A and F72B with PLC



Inputs:

1. **Heat Sensor.** It could be installed in the kitchen and works as the trigger to power on the system fan and EAC.
2. **BMS Wash.** Controls wash cycle from Building Management System.
3. **Detergent Tank Sensor.** There is flashing warning to indicate a low detergent level in the tank.
4. **Ansul Control.** Turns fan on and everything else off.






Figure 11 – Field Wiring Schematic

- IMPORTANT -

Before putting F72 Electronic Air Cleaner into service, check through the following items to be sure it is properly installed.

- 1. If outdoor air is used, care must be taken to prevent direct delivery of cold outside air across the electronic cell. Preheat the air in some manner or mix with return air.**
- 2. Check over the installation for correct sheet-metal and electrical work.**
- 3. Turning vanes should be used in duct elbow to provide even air distribution across the cell.**
- 4. When it is necessary to change the duct size close to the air cleaner, use gradual transitions to reduce turbulence.**

General Component Inspection

1. Check for proper orientation of the electronic cells. Airflow arrows must point downstream. Impingers must be on both sides of the electronic cells.
2. Be sure that the electronic cells and impingers are clean, dry and free of foreign objects.

Check the Junction Box Connections

Check all electrical connections to make certain they are correct and complete. Refer to the hookup diagrams (Figures 7 through 10).

Check the Electronic Cells and the Power Supply

With all components in place and the access door closed turn on the electronic air cleaner. Check the indicator light on the power door. It should be on. With the power supply energized, momentarily open the access door. When the door opens the indicator light should go out. If the power supply and electronic cells do not check out properly in this procedure, refer to the **Troubleshooting** section for additional checks.

- CAUTION -

Always disconnect the power to F72 before working on or near the air cleaner.

When to Wash the Electronic Cells

To maintain peak performance and efficiency, the electronic cells and spray shields in the electronic air cleaner must be washed regularly. This washing is necessary to remove the dirt particles accumulated during the air cleaning process.

The cells and screens should be visually checked for dirt. Experience will probably be the best indicator of how often the cells and screens should be cleaned. For example, when operating in a thick smoke or particularly dirty atmosphere, the cells may need washing twice a week. If the dirt accumulation is light, the period between washings can be lengthened.

Manually Cleaning

Cleaning the Impingers

The impingers in front of the electronic cells help stop the large particles. The impingers should be periodically removed to clean off the accumulated dirt. It's a good idea to wash these impingers at the same time as the cells to be sure they are not overloaded. An overloaded impinger can restrict the airflow.

Remove the Cells and the Impingers

1. Discharge cell by pressing test button or grounding out the collector contact.
2. Use care to avoid damage to the collector plates when handling and washing the cells.
3. Pull the handle to slide the cells out. Note the direction of the airflow arrows on the cells.
4. Pull the impinger out. Clean the dirt in the cell or impinger tracks.




Figure 12 – PN 38010, Electronic Cell Components. Dimensions in Inches [Millimeters Shown in Brackets].



Manually Cleaning (continued)

Manually Cleaning Cells

Depending on the type of contaminant, different cleaners will be required. SMOKEMASTER® liquid detergent will be adequate to remove almost any type of dust, dirt, pollen and tobacco smoke. A cleaner, such as AQE's welding detergent part number 45026, will remove metal oxides such as those produced by welding. A cleaner, such as AQE's degreaser part number 45031, will remove greases associated with kitchen hoods.

- CAUTION -

Do NOT splash the cleaning solution in your eyes and avoid prolonged contact with your skin. Keep the detergent and solution out of the reach of children. Be sure to follow the cleaning solution label instructions for use or storage.

1. Mix the cleaning solution according to the label instructions.
2. Soak the cells for the time indicated on the cleaning solution label. Before removing the cells, slosh them around several times.
3. Rinse the cells with a fine spray.
4. Soak the cells and let the water drain. If the water draining from the cells feels slippery, they need more rinsing.
5. Inspect the cells for cleanliness. If any dirt remains, it probably indicates that the cells should be washed more frequently. Repeat this soaking procedure, if needed, to get the cells clean.

Return the Electronic Cells and the Impingers to the Unit

1. Place the electronic cell so that the arrow on the handle-side of the cell points in the direction of the airflow.
2. Insert the impingers in the channels provided.
3. Close the filter access door.

Ionizing Wire Replacement

The fine wire electrodes in the charging section of the electronic cell may break or become damaged. During operation, a broken or deformed wire generally causes a short to ground, possibly with visible arcing or sparking. This condition, or any other short in the charging section, is indicated by the status light on the power door. Broken wires must be replaced. Remove all parts of the broken wire and temporarily use the cell with missing wire(s) until it can be replaced as directed below.

To replace the ionizing wires, remove the electronic cell from the cabinet and proceed as follows:

1. Remove all of the broken wire from the cell mounting brackets.
See Figure 13.
2. Install the new wire.

Insert the crimped end of the ionizing wire into the keyhole then hook the spring into the mounting bracket hole.

Use a long nose pliers and carefully pull the spring until the hooked end can be secured in the mounting bracket hole.




Figure 13 – Method of Replacing the Ionizing Wire

- WARNING! -

The following instructions are intended for qualified service personnel only. Dangerous line voltage circuits are exposed during this procedure. Disconnect the power before servicing the unit. Voltage may exceed 12,000 VDC.

Make sure meter to be used has appropriate voltage rating.

Before beginning this section make sure to review the checkout and maintenance sections!

Make sure all wiring is connected properly reference figures 7 and 8.

Indicator Light Flickers / Unit Makes Zapping Noises

Some flicker is inherent in neon indicator lights and is not an indication that anything is wrong. If the indicator light blinks off and back on and is accompanied by a clicking or zapping noise that is frequent, it is an indication that the electronic collector cell(s) may be dirty or damaged. An occasional blink or snapping is normal.

If the wash cycle does not eliminate the noise remove the cells and investigate them looking for bent collector fins or a large particle stuck in a cell. Also check the contacts on the cells and inside the unit for a possible bad connection. Remove any particles taking care not to bend the collector plates or break any ionizing wires.

If any ionizing wires are broken reference the parts list for replacement.

If a collector plate is bent causing the arcing (bug zapper noise), one may attempt to bend the plate back to an original position with a duckbilled pliers. Care must be used as further damage can be caused by stretching the aluminum plates, which can render the cell unrepairable. Please contact Air Quality Engineering, Inc. at 1-800-328-0787 for assistance.

Indicator Light is **NOT** On

Check to see if the cell access door is closed properly. The indicator light will not be lit if the door is open and the electronic cells will not be energized.

Be sure the electrical connections have been made properly per Figure 7 & 8.

Remove the electronic collector cell(s) and close the door. If the light comes back on, there is a short in at least one collector cell. A short can be a result of the cell(s) being excessively dirty, a large piece of contaminant shorting the fins, or a physical damage such as a collector fin being bent out of shape and touching an adjoining fin. The wash cycle may be run to clean the cells if they appear dirty. Visually inspect the cell for large particulate that may be bridging two adjoining collector fins or for physical damage. If damage is identified, repairs should only be performed by trained personnel as improper repairs may result in unrepairable damage. Please contact Air Quality Engineering, Inc. at 1-800-328-0787 for assistance.

If the indicator light does not come on with the cells removed and the door closed, use a voltmeter to confirm that there is indeed voltage at the input of the power supply. If there is voltage at the power supply, but no indicator light, the power supply should be replaced. The indicator light itself has a very low failure rate.



The SMOKEMASTER F72 series of pollution control units (PCU's) can be optionally furnished with factory pre-piped ANSUL R-102 fire suppression nozzles and fusible link detectors.

ANSUL R-102 Fire Suppression pre-piping is installed by AQE per recommendations and guidelines from ANSUL (Johnson Controls)

The additional components of the PCU's fire suppression system (tanks, controls, field connections etc.) must be provided and installed by an ANSUL factory trained, certified and authorized technician.

The ANSUL® R-102™ Restaurant Fire Suppression System is an automatic, pre-engineered, fire suppression system designed to protect areas associated with ventilating equipment including hoods, ducts, plenums, and filters. The system also protects auxiliary grease extraction equipment and cooking equipment such as fryers; griddles and range tops; upright, natural charcoal, or chain-type broilers; electric, lava rock, mesquite, or gas-radiant char-broilers; and woks.

The system is ideally suitable for use in restaurants, hospitals, nursing homes, hotels, schools, airports, and other similar facilities.

Use of the R-102 system is limited to indoor applications or locations that provide weatherproof protection within tested temperature limitations. The regulated release and tank assemblies must be mounted in an area where the air temperature will not fall below 32 °F (0 °C) or exceed 130 °F (54 °C). The system must be designed and installed within the guidelines of the UL/ULC Listed Design, Installation, Recharge, and Maintenance Manual.



ANSUL R-102 FIRE SUPPRESSION SYSTEM NOTES:

Model	Precipitator Nozzles	Odor Control Module Nozzles	Total Nozzles
SMOKEMASTER® F72A	1Nx4	1Nx8 and 2Wx1	1Nx12 and 2Wx1
AUTOCLEAN® 2000	1Nx4	1Nx8 and 2Wx1	1Nx12 and 2Wx1
SMOKEMASTER® F72B	1Nx4	1Nx8 and 2Wx2	1Nx12 and 2Wx2
AUTOCLEAN® 4000	1Nx4	1Nx8 and 2Wx2	1Nx12 and 2Wx2
SMOKEMASTER® F72C	1Nx8	1Nx16 and 2Wx4	1Nx24 and 2Wx4
AUTOCLEAN® 8000	1Nx8	1Nx16 and 2Wx4	1Nx24 and 2Wx4


1. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT ANSUL R-102 MANUAL (P/N: 418087).
2. FOR DUCTWORK BEYOND THE EXHAUST FAN OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.



R-102 FIRE SUPPRESSION SYSTEM NOTES:

- 1.1. TOTAL NOZZLES 4 (4 1N)
- 1.2. 4 1N NOZZLES AT AUTO CLEAN F72 INLET
- 2. ALL NOZZLE MANIFOLDS COME IN FROM BACK SIDE
- 2.1. ACCESS SIDE IS ON THE BACK SIDE OF THE POU
- 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (P/N 419067).
- 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE POU AND PLACED NOMINALLY CENTER.
- 5. FOR DUCTWORK BEYOND THE EXHAUST FAN OUTLET, ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow P#
1N	1	4	4
2W	2	0	0




ANSUL R-102 PRE-PIPING FOR AUTO CLEAN 2000 OR F72A	
Rev: 3	At Quality Engineering
Date: 01/4/23	Phone: (888) 883-9273
Approved by: AJN	Fax: (763) 531-0900
	www.AirQuality-Eng.com

SMOKEMASTER® F72 Fire Suppression Factory Pre-Piping

- R-102 FIRE SUPPRESSION SYSTEM NOTES:**
- 1. TOTAL NOZZLES 4 (4 IN)
 - 1.1. 4 IN NOZZLES AT AUTO CLEAN/F72 INLET
 - 2. ALL NOZZLE MANIFOLDS COME IN FROM BACK SIDE
 - 2.1. ACCESS SIDE IS ON THE BACK SIDE OF THE POU
 - 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (PIN 418087).
 - 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE POU AND PLACED NOMINALLY CENTER.
 - 5. FOR DUCTWORK BEYOND THE EXHAUST FAN/OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow Pt
1N	1	4	4
2W	2	0	0



ANSUL R-102 PRE-PIPING FOR
AUTO CLEAN 4000 OR F72B

Rev: 3
Date: 9/14/23
Approved by: AJN


Air Quality Engineering
Phone (888) 883-3273
Fax (763) 531-9900
www.Air-Quality-Eng.com

SMOKEMASTER® F72 Fire Suppression Factory Pre-Piping



- R-102 FIRE SUPPRESSION SYSTEM NOTES:**
1. TOTAL NOZZLES 8 (8 IN)
 - 1.1. 8 IN NOZZLES AT AUTO CLEAN F72 INLET
 2. ALL NOZZLE MAINFOLDS COME IN FROM BACK SIDE
 - 2.1. ACCESS SIDE IS ON THE BACK OF THE PCU
 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (PIN 418087)
 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE PCU AND PLACED NOMINALLY CENTER.
 5. FOR DUCTWORK BEYOND THE EXHAUST FAN OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow Pl.
1N	1	8	8
2W	2	0	0





ANSUL R-102 PRE-PIPING FOR
SAUTOCLEAN 8000 OR F72C

Rev 3
Date: 8/1/23
Approved by: AIN

Air Quality Engineering
Phone (888) 883-3273
Fax (763) 531-9900
www.Air-Quality-Eng.com


- R-102 FIRE SUPPRESSION SYSTEM NOTES:**
1. TOTAL NOZZLES TO 2" IN AND 2W:
 - 1.1 2" IN AT ODOR MODULE INLET
 - 1.2 6" IN BETWEEN CARBON MODULE V-BANK
 - 1.3 1 2W NOZZLES AT OUTLET FOR FAN
 2. ALL NOZZLE MANIFOLDS COME IN FROM BACK SIDE.
 - 2.1. ACCESS SIDE IS ON THE BACK SIDE OF THE ODOR MODULE
 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (PIN: 418087).
 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE POU AND PLACED NOMINALLY CENTER.
 5. FOR DUCTWORK BEYOND THE EXHAUST FAN OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.
 6. THE ODOR MODULE IS COMPOSED OF BIRTHITE CARBON FILTER SECTION AND THE MERV14 SECTION AS SHOWN IN THE TOP VIEW.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow Pt
1N	1	8	8
2W	2	1	2




TANK
(NOT PROVIDED BY AQE)

BACK SIDE VIEW
(OPPOSITE ACCESS DOORS)



SECTION B-B
MERV FILTER NOZZLE CONFIGURATION
ODOR MOD SECTION







SECTION C-C
FAN NOZZLE CONFIGURATION
(NOZZLES ARE SPRAYING OUT OF PAGE)
OUTLET VIEW



- R-102 FIRE SUPPRESSION SYSTEM NOTES:**
- 1. TOTAL NOZZLES 10 (8 1IN AND 2 2W)
 - 1.1. 2 1IN AT ODOR MODULE INLET
 - 1.2. 6 1IN BETWEEN CARBON MODULE V-BANK
 - 1.3. 2 2W NOZZLES AT OUTLET FOR FAN
 - 2. ALL NOZZLE MANIFOLDS COME IN FROM BACK SIDE
 - 2.1. ACCESS SIDE IS ON THE BACK SIDE OF THE ODOR MODULE
 - 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (P/N 410007).
 - 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE POU AND PLACED NOMINALLY CENTER
 - 5. FOR DUCTWORK BEYOND THE EXHAUST FAN OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow Pt
1N	1	8	8
2W	2	2	4



ANSUL R-102 PRE-PIPING FOR
ODOR CONTROL MODULE
THAT PAIRS WITH
AUTOCLEAN 4000 OR F72B




Rev: 3
Date: 9/14/23
Approved by: AJN

Air Quality Engineering
Phone (688) 883-3273
Fax (763) 531-9900
www.Air-Quality-Eng.com



- B.102 FIRE SUPPRESSION SYSTEM NOTES:**
- 1. TOTAL NOZZLES 20 (16 1IN AND 4 2W)
 - 1.1 4 1IN AT ODOR MODULE INLET
 - 1.2 12 1IN BETWEEN CARBON MODULE & BANK
 - 1.3 4 2W NOZZLES AT OUTLET FOR FAN
 - 2. ALL NOZZLE MANIFOLDS COME IN FROM BACK SIDE
 - 2.1 ACCESS IS ON BACK SIDE OF THE PCU
 - 3. ALL DISCHARGE PIPING TO FOLLOW THE LIMITATIONS AND PARAMETERS PER THE CURRENT R-102 MANUAL (PN 418087)
 - 4. A FUSIBLE LINK IS TO BE PLACED AT THE INLET AND OUTLET OF THE PCU AND PLACED NORMALLY CENTER.
 - 5. FOR DUCT WORK BEYOND THE EXHAUST FAN OUTLET ADDITIONAL PROTECTION IS REQUIRED IN THE FORM OF NOZZLES AND FUSIBLE LINKS WHERE APPROPRIATE.

Flow Points			
Nozzle Type	Nozzle Flow Point	Nozzle Qty	Total Flow Pt
1IN	1	16	16
2W	2	4	8



ANSUL R-102 PRE-PIPING FOR
ODOR CONTROL MODULE
THAT PAIRS WITH
AUTOCLEAN 8000 OR F728

Rev. 3
Date: 9/17/23
Approved by: AIN

Air Quality Engineering
Phone (888) 883-3273
Fax (763) 331-9900
www.AirQuality-Eng.com

ONE-YEAR LIMITED WARRANTY

Air Quality Engineering, Inc. (AQE), warrants to the original purchaser, subject to the conditions below, that if the "Product" covered by this warranty should fail to perform by reason of improper workmanship or material, AQE will during the period of one (1) year from the date of original purchase either (i) replace the product or (ii) provide all necessary parts to repair the product without charge. The decision to replace the product or the necessary parts shall rest solely with AQE. This warranty is valid only under the following conditions:

CONDITIONS

1. AUTHORIZATION: The purchaser will contact AQE at (763) 531-9823 for authorization, returned goods number (RGA) and the shipping address. AQE will direct the purchaser to either return the necessary parts or the product at AQE's option.
2. PROPER DELIVERY: The shipping, freight prepaid or delivery of the parts or the product to AQE in either its original carton or in a carton assuring similar protection of the product with the returned goods number (RGA) clearly displayed on the outside of the carton.
3. UNAUTHORIZED REPAIR: A showing by the original purchaser that the product has not been altered, repaired or serviced by anyone other than an authorized service technician using genuine AQE parts.
4. UNAUTHORIZED PARTS: A showing by the original purchaser that the product has had only genuine AQE parts and filters used in its operation and maintenance.
5. SERIAL NUMBER INTACT: A showing by the original purchaser that the serial number has not been altered or removed.
6. MISUSE: A showing by the original purchaser that the product has not been involved in an accident, freight damaged, misused, abused or operated contrary to the instructions contained in the Owner's Manual.

Air Quality Engineering, Inc.'s sole responsibility shall be to repair or replace the product within the terms stated above. AQE SHALL NOT BE LIABLE FOR ANY CONSEQUENTIAL DAMAGES RESULTING FROM ANY BREACH OF WARRANTY, EXPRESS OR IMPLIED, APPLICABLE TO THIS PRODUCT. Some states do not allow the exclusion or limitation of consequential damages so this limitation may not apply to you.

THIS WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, AND THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE HEREBY EXCLUDED BEYOND THE ONE-YEAR DURATION OF THIS WARRANTY. Some states do not allow limitations on how long an implied warranty lasts so the above limitation may not apply to you.

This warranty gives you specific legal rights and you may also have other rights that vary from state to state.

AIR QUALITY ENGINEERING, INC.
7140 NORTHLAND DRIVE NORTH
MINNEAPOLIS, MINNESOTA 55428-1520

TOLL FREE: 1-800-328-0787
TELEPHONE: 763-531-9823
FAX: 763-531-9900

MANUFACTURER & WORLDWIDE DISTRIBUTOR OF SMOKEMASTER® AIR CLEANING SYSTEMS

Printed in the USA